

All India Institute of Medical Sciences Jodhpur

Date: - 10th November, 2015

Corrigendum

for

Laboratory Benches Furniture & Fixtures

NIT Issue Date : 16th October, 2015.

NIT No. : Admn/Tender/17/2015-AIIMS.JDH

Pre Bid Meeting held on : 28th October, 2015 at 03:00 PM

Last Date of Submission : 16th November, 2015 at 03:00 PM

Revised Lase Date of Submission : 30th November, 2015 at 03:00 PM

1. The following revised and additional specification will be added:-

1. Page No. 14, QUALITY ASSURANCE, Point No. 1.2:

For

Bidder shall attach the third party test certificates of the furniture systems as per SEFA 8-M duly certified by SEFA approved laboratory within the last two years.

Read

Bidder shall attach the third party test certificates of the furniture systems as per SEFA 8-M duly certified by NABL/SEFA approved laboratory within the last two years.

2. Page No. 15, PERFOMANCE REQUIREMENTS, Point No. c, after Point No. 5: Para Added:

(Bidder shall follow all steel finish & test in line with SEFA 8-M 2010 Subsection 8)

3. Page No. 16, Requirement for cabinets, Para 5:

For

Drawer Slides: Shall be CED coated Black colour Heavy Duty Double Extension Ball bearing roller Slides.

Read

Drawer Slides: Shall be Heavy Duty Double Extension Ball bearing roller Slides preferably CED coated Black colour.

4. Page No. 18, Annexure-II, Point No. 1.12 (INSTALLATIONS), Inside Table, Row No. 03:

For

3	HINGES	HETTICH,HAFFLE (GERMANY)		
Read				
3	HINGES	HETTICH/ HAFFLE/ EBCO/ GODREJ		

5. Page No. 18, Annexure-II, Point No. 1.12 (INSTALLATIONS), Inside Table, Row No. 03:

For

4	LOCKS	HETTICH, HAFFLE (GERMANY)		
Read				
4	LOCKS	HETTICH/ HAFFLE/ EBCO/ GODREJ		

6. Page No. 21, Point No. 8, Peg Board with 25 Pegs:

Para Added

MOC for Peg Board - minimum 6 mm thick Phenolic Resin Chemical Resistant Laminate or Acrylic.

7. Page No. 21, Point No. 10, CHEMICAL FLOOR STANDING STORAGE CABINET:

Para Added

MOC for Chemical Storage Cabinet - minimum 1.2 mm thick Epoxy Coated Galvanised GI Steel.

8. Page No. 21, Point No. 11, STANDALONE CABINET:

Para Added

MOC for Standalone Cabinet - minimum 1.2 mm thick Epoxy Coated Galvanised GI Steel.

Administrative Officer AIIMS Jodhpur