

**Invitation of quotation**  
**for**  
**Electrical Items**  
**At**  
**AIIMS Centre for Rural Health, Dhawa (Distt-  
Jodhpur)**

Inquiry No.: : Admn/Gen/02-02/2016-AIIMS.JDH

Inquiry Issue Date : 22<sup>nd</sup> June, 2016

Last Date of Submission : 28<sup>th</sup> June, 2016 at 05:00 PM.



**All India Institute of Medical Sciences, Jodhpur**

Basni Phase - II, Jodhpur – 342005, Rajasthan

Telefax: 0291- 2012978, email: [procurement@aiimsjodhpur.edu.in](mailto:procurement@aiimsjodhpur.edu.in)

[www.aiimsjodhpur.edu.in](http://www.aiimsjodhpur.edu.in)

**Invitation of quotation for Electrical Items at AIIMS Jodhpur**

Sealed Quotations are hereby invited by the undersigned on behalf of the Director, AIIMS Jodhpur for supply of Electrical Items for the AIIMS Centre for Rural Health, Dhawa (Distt-Jodhpur) as per terms & conditions mentioned below. The filled quotations along with all the required document must reach in the office of the undersigned on or before 28.06.2016 05.00 PM. The Envelope containing the quotation would please be sealed and super scribed as under:-

**“QUOTATION FOR SUPPLY OF ELECTRICAL ITEMS AGAINST  
INQUIRY NO. ADMN/GEN/02-02/2016-AIIMS.JDH”  
DUE ON 28.06.2016 05.00 PM”**

**1. Terms & Conditions:**

- A) The quotations received after this deadline & unsealed shall not be entertained under any circumstances whatsoever. In case of postal delay this Institute will not be responsible.
- B) Quotations must be in the enclosed prescribed Performa on the letter head of the firm duly signed by the Proprietor/ Partner/ Director or their authorized representative, In case of signing of quotation by the authorized representative letter of authorization must be attached with the quotation.
- C) Bidder must quote the product as per specification provided in Annexure 1.
- D) Rates must be quoted in **Indian rupees** and as per the format specified taxes extra if any must be written separately.
- E) Rates must be quoted FOR basis (including Freight charges, Insurance, installation etc.).
- F) No overwriting or cutting is permitted in the rate. If found, the quotation shall be summarily rejected.
- G) The rates quoted must be valid for 60 days minimum from the date of opening of the quotation and silence of any tendered on this issue shall be treated as agreed with this condition.
- H) Becoming L1 will not be the criteria for awarding of purchase order unless the rates are reasonable & justified.
- I) RTGS/NEFT details need to be furnished by the supplier with the quotation on the letter head of supplier/firm/agency.
- J) The firm/agency may satisfy the following conditions and attach self-attested copy of the same with the quotation:
- Firm shall be registered with the Government of Rajasthan / Central Government.
  - The firm shall have valid VAT/ Sales Tax No. and IT PAN.
  - **The firm should not be black listed by any Govt. Agency/Dept.**
- K) Quotations qualified by such vague and indefinite expressions such as “subject to prior

**INQUIRY NO. Admn/Gen/02-02/2016-AIIMS.JDH**

confirmation”, “subject to immediate acceptance” etc. will be treated as vague offers and rejected accordingly. Any conditional quotation shall be rejected summarily.

- L) **Delivery Period** – within 15 days from Purchase order.
- M) **Liquidated Damage:** - If the supplier fails to deliver the material on or before the stipulated date, then a penalty at the rate of 0.5 % per week of the total order value shall be levied subject to maximum of 10% of the total order value.
- N) **Payment Terms:** Payment will be only after satisfactorily delivery / commissioning of material and after inspection by the AIIMS Jodhpur.
- O) **Disputes:** -In the event of any dispute or disagreement arising between the contractors and any other department of AIIMS Jodhpur with regards to the interpretation of “Terms & Conditions” of this inquiry, the same shall be referred to the Director, AIIMS Jodhpur whose decision will be final and binding upon the contractor.
- P) AIIMS, Jodhpur reserves the right to increase or decrease quantity and / or amount of work. Decision of Quantity of material in the AIIMS, Jodhpur will be final in this regard.
- Q) AIIMS, Jodhpur reserves the right to reject any quotation or part or the whole of inviting quotation process without assigning any reason. Decision of the AIIMS, Jodhpur will be final in this regard.

**2. Special Terms & Conditions:**

- A) Items must be dropped at AIIMS Centre for Rural Health, Dhawa (Distt-Jodhpur) on free of cost.
- B) The supplier may be asked to submit a sample of the product(s), which will be evaluated by a technical evaluation committee. The expenditure incurred for demonstrating the items will be borne by the supplier.

**Administrative Officer**

Encl.: Annexure 1 (Specification)  
Annexure 2 (Format of price bid)

**Annexure 1****Specification**

S. No	DSR No.	Make	Detail of Item	Unit	Qty.
1	1756	LEGRAND/ HAVELLS/ SCHNEIDER	8 Way (4+24) double door, horizontal type TP & N, sheet steel, MCB distribution board, 415 volts, on surface/recess, complete with tinned copper bus bar, neutral bus bar, earth bar, din bar, inter-connections, powder painted including earthing etc. complete in all respect.	No.	1
2	1715	LEGRAND/ HAVELLS/ SCHNEIDER	63 Amp, 4-pole, 415 volts, and isolator in the existing DB complete in all respect.	No.	1
3	1706	LEGRAND/ HAVELLS/ SCHNEIDER	1-phase, 230 volt, 16Amps, sp MCB, "C" curve, 10KA breaking capacity	Nos.	7
4	1706	LEGRAND/ HAVELLS/ SCHNEIDER	1-phase, 230 volt, 25Amps, sp MCB, "C" curve, 10KA breaking capacity	Nos.	3
5	1706	LEGRAND/ HAVELLS/ SCHNEIDER	1-phase, 230 volt, 32Amps, sp MCB, "C" curve, 10KA breaking capacity	Nos.	2
6	1710	LEGRAND/ HAVELLS/ SCHNEIDER	3-phase, 415 volt, 32Amps, TPN MCB, "C" curve, 10KA breaking capacity	No	1
7	1732	LEGRAND/ HAVELLS/ SCHNEIDER	32 Amps, 415 volts, TP & N industrial type, socket outlet, with 4 pole and earth, metal enclosed plug top in sheet steel enclosure on surface or in recess, with chained metal cover for the socket outlet.	No.	1
8	1730	LEGRAND/ HAVELLS/ SCHNEIDER	25 Amps, 240 volts, SPN industrial type, socket outlet, with 2 pole and earth, metal enclosed plug top in sheet steel enclosure on surface or in recess, with chained metal cover for the socket outlet.	No.	1
9	1102	POLYCAB/ FINOLEX	2.5 sqmm FRLS PVC insulated flexible copper conductor ISI marked of 1.1 KV grade	Mtr.	270
10	1103	POLYCAB/ FINOLEX	4 sqmm FRLS PVC insulated flexible copper conductor ISI marked of 1.1 KV grade	Mtr.	270
11	1104	POLYCAB/ FINOLEX	6 sqmm FRLS PVC insulated flexible copper conductor ISI marked of 1.1 KV grade	Mtr.	90
12	1106	POLYCAB/ FINOLEX	4 Core x 16 sqmm FELS PVC insulated & unsheathed flexible copper conductor ISI marked of 1.1 KV grade	Mtr.	50
13	1125	PRECISION/ BEC	25 mm dia. ISI marked, PVC conduit	Mtr.	90
14	NS	LEGRAND/ HAVELLS/ SCHNEIDER	100 Amps MCCB with encloser (415 volts, board of sheet steel dust protected, duly powder painted)	No.	1

**INQUIRY NO. Admn/Gen/02-02/2016-AIIMS.JDH**

15	NS	ANCHOR/ ROMA	PVC S.S combine switch	Nos.	15
16	NS	ISI make	10 swg size copper earth wire.	Mtr.	60
17	NS	Any ISI make	25 mm PVC clit	Pkg.	1
18	NS	Any ISI make	25 mm wooden screw	Pkg.	2
19	NS	Any ISI make	25 mm PVC plug	Pkg.	1
20	NS	ANCHOR/BEC	PVC insulated electrical tape	Nos.	10

**Administrative Officer**

**[On the letterhead of firm]**

**ANNEXURE "2"**  
**PRICE BIDFORM**

To,  
Administrative Officer,  
AIIMS, Jodhpur.

Dear Sir,

1. I/We ..... Submitted the quotation for Enquiry No. "QUOTATION FOR SUPPLY OF ELECTRICAL ITEMS AT AIIMS AGAINST THE INQUIRY NO. Admn/Gen/02-02/2016-AIIMS.JDH" DUE ON 28.06.2016 05.00 PM for supply of Electrical Items at AIIMS Jodhpur".

2. I/We thoroughly examined, understood and accepted terms & conditions given in the enquiry document, failing which my quotation will be rejected out rightly.

3. I/We hereby offer to supply at the following rates.

S. No	Detail of Item	Unit	Qty.	Make	Price/Unit Exclusive of TAX (INR)	TAX %	Price/Unit inclusive of TAX (INR)	Total Amount Inclusive of TAX (INR)
1	8 Way (4+24) double door, horizontal type TP & N, sheet steel, MCB distribution board, 415 volts, on surface/recess, complete with tinned copper bus bar, neutral bus bar, earth bar, din bar, inter-connections, powder painted including earthing etc. complete in all respect.	No.	1					
2	63 Amp, 4-pole, 415 volts, and isolator in the existing DB complete in all respect.	No.	1					
3	1-phase, 230 volt, 16Amps, sp MCB, "C" curve, 10KA breaking capacity	Nos.	7					
4	1-phase, 230 volt, 25Amps, sp MCB, "C" curve, 10KA breaking capacity	Nos.	3					
5	1-phase, 230 volt, 32Amps, sp MCB, "C" curve, 10KA breaking capacity	Nos.	2					
6	3-phase, 415 volt, 32Amps, TPN MCB, "C" curve, 10KA breaking capacity	No	1					
7	32 Amps, 415 volts, TP & N industrial type, socket outlet, with 4 pole and earth, metal	No.	1					

**INQUIRY NO. Admn/Gen/02-02/2016-AIIMS.JDH**

	enclosed plug top in sheet steel enclosure on surface or in recess, with chained metal cover for the socket outlet.							
8	25 Amps, 240 volts, SPN industrial type, socket outlet, with 2 pole and earth, metal enclosed plug top in sheet steel enclosure on surface or in recess, with chained metal cover for the socket outlet.	No.	1					
9	2.5 sqmm FRLS PVC insulated flexible copper conductor ISI marked of 1.1 KV grade	Mtr.	270					
10	4 sqmm FRLS PVC insulated flexible copper conductor ISI marked of 1.1 KV grade	Mtr.	270					
11	6 sqmm FRLS PVC insulated flexible copper conductor ISI marked of 1.1 KV grade	Mtr.	90					
12	4 Core x 16 sqmm FELS PVC insulated & unsheathed flexible copper conductor ISI marked of 1.1 KV grade	Mtr.	50					
13	25 mm dia. ISI marked, PVC conduit	Mtr.	90					
14	100 Amps MCCB with encloser (415 volts, board of sheet steel dust protected, duly powder painted)	No.	1					
15	PVC S.S combine switch	Nos.	15					
16	10 swg size copper earth wire.	Mtr.	60					
17	25 mm PVC clit	Pkg.	1					
18	25 mm wooden screw	Pkg.	2					
19	25 mm PVC plug	Pkg.	1					
20	PVC insulated electrical tape	Nos.	10					

Date \_\_\_\_\_

Place \_\_\_\_\_

(Signature of Authorized Person) \_\_\_\_\_

(Name) \_\_\_\_\_

Name of Firm/Company/Agency \_\_\_\_\_

Phone No. \_\_\_\_\_

Email: \_\_\_\_\_