

**Invitation of Quotation for Supply, installation, Testing and commissioning
(SITC) of RO Systems in series with existing purification cum cooling system at
New Girls Hostel in AIIMS, Jodhpur.**

Inquiry No.	AIIMS/Jodh./E.E. (E)/Q.N./2024-25/05
Inquiry Issue Date	15 May, 2024
Last Date of Submission	22 May, 2024 at 03:00 PM



All India Institute of Medical Sciences, Jodhpur
Basni Phase - II, Jodhpur - 342005, Rajasthan
Telefax: 0291- 2012978 www.aiimsjodhpur.edu.in

ALL INDIA INSTITUTE OF MEDICAL SCIENCES, JODHPUR
अखिल भारतीय आयुर्विज्ञान संस्थान, जोधपुर

Inquiry No.: AIIMS/Jodh./E.E.(E)/Q.N./2024-25/05

Date: 15 May 2024

QUOTATION NOTICE

Sealed Quotations are invited from the Authorize Dealer/Supplier/Firms of makes as mentioned in Special Terms & Conditions on behalf of the Executive Director, AIIMS Jodhpur for the Works “**Supply, installation, Testing and commissioning (SITC) of RO Systems in series with existing purification cum cooling system at New Girls Hostel in AIIMS, Jodhpur**”. The last date of submission of quotation is **22 May 2024 up to 3:00 PM**.

General Terms and Conditions:

1. The quotations received after 22 May 2024 up to 3:00 PM or unsealed shall not be entertained under any circumstances whatsoever. In case of postal delay, this Institute will not be responsible. The offer Submitted by/through Fax/Email shall not be considered and no correspondence will be entertained in this matter.
2. Quotations must be in the enclosed prescribed format duly signed by the Proprietor/Partner/Director or their Authorized Representative, in case of signing of quotation by the authorized representative letter of authorization must be attached with the quotation. Quotation must be dropped in “Quotation Box” located in Administration Block of AIIMS, Jodhpur. Quotation must be in a sealed envelope super scribed with inquiry number.
3. Rates must be quoted in “Indian Rupees” and bidder should give rates, showing taxes, levies, if any, in the prescribed format. Quotation not conforming to these requirements shall be rejected and no correspondence will be entertained whatsoever.
4. Rates must be quoted FOR basis (including Freight charges, Insurance, installation, commissioning, etc.)
5. No overwriting or cutting is permitted in the rate. If found, the quotation shall be summarily rejected.
6. The rates quoted must be valid for 90 days minimum from the date of opening of the quotation.
7. L1 will be decided on composite basis. Becoming L1 will not be the criteria for awarding of work unless the rates are reasonable & justified.
8. RTGS/NEFT details need to be furnished by the bidder with the quotation on the Annexure A.
9. Quotations qualified by such vague and indefinite expressions such as “subject to prior confirmation”, “subject to immediate acceptance” etc. will be treated as vague offers and rejected accordingly. Any conditional quotation shall be rejected summarily.
10. The time allowed to complete the supply & installation of required RO System is 30 days from the date of issue of work order.
11. Bidders must supply & install the items as per directions of Engineer In-charge for the works.
12. If the supplier/vendor/contractor fails to supply & install the required material on or before the stipulated date, then the institute has right to reject the quotation or to take necessary action.
13. Payment Terms: - Payment will be made only after satisfactory completion of work within stipulated time and after inspection by the AIIMS Jodhpur on producing GST Invoice.
14. Disputes: In the event of any dispute or disagreement arising between the contractors and any other department of AIIMS Jodhpur with regards to the interpretation of “Terms & Conditions” of this inquiry, the same shall be referred to the Executive Director, AIIMS Jodhpur whose decision will be final and binding.
15. AIIMS, Jodhpur reserves the right to reject any quotation or part or the whole of inviting quotation process without assigning any reason. Decision of the Executive Director, AIIMS, Jodhpur will be final in this regard.
16. GST shall be paid extra as per actual rate.

Special Terms & Conditions:

1. Bidder must quote rate in Price Bid Form provided in Annexure A.
2. Bidder must attach the Authorization certificate of Ion Exchange / Eureka Forbes / Kent.
3. Technical Specification are as per Annexure B.
4. Bidders are recommended to visit the site at AIIMS Jodhpur before quoting the rates. It will be automatically understood that the bidder has visited the site before quoting the price. No claim whatsoever will be entertained in this regard.


Executive Engineer(E)

Annexure A.

Price Bid Form

To,
The Executive Engineer (Electrical),
AIIMS, Jodhpur.

Dear Sir,

1. I/We M/s _____ submitting the quotation for Enquiry No. AIIMS/Jodh./E.E.(E)/Q.N./2024-25/... at AIIMS Jodhpur".
2. I/We thoroughly examined, understood and accepted terms & conditions given in the enquiry document, failing which my quotation will be rejected out rightly.
3. I/We hereby offer to supply at the following rates:

S. No.	Details of Items	Qty. (nos.)	Rate	Amount
1.	Anti-scalant Dosing Pump (Any ISI make) 6LPH	2		
2.	Pump Vertical Multistage (Grundfos, KBL, Willo, CRI) 2.5 m3/Hr, Operation pressure 5-10kg/cm2	2		
3.	RO Membrane 4" X 40" Long (Make:- Ion Exchange / Eureka Forbes / Kent)	2		
4.	RO Membrane Housing (compatible with the unit)	2		
5.	Low Pressure Switch, 0.5 To 5 Bar	2		
6.	Dosing Tank 50 Liters Capacity	2		
7.	Nylon Tube 5 Mtr	4		
8.	Pressure Gauge, 0 - 16 Kg/cm2	6		
9.	Anti-scalant Chemical In 5L CAN	1		
10.	PVC Fitting & support as required	2		
Total Amount (Excl. GST)				

- ✓ GST shall be paid extra as per actual rate.
- ✓ L1 will be decided on composite basis. Becoming L1 will not be the criteria for awarding of work unless the rates are reasonable & justified.

Date _____
Place _____
Signature of Authorised Person: _____
Name of the Firm/Agency: _____
Phone No: _____
Firm GST No: _____
Bank Account No. :- _____
IFSC Code: _____
Seal:- _____

Annexure B.

Technical Specifications:

S.No.	Parameters	Description
1.	Flow	250 Litre per Hour
2.	Recovery Rate	50-60 %
3.	Max. inlet water (TDS)	1500 PPM
6.	Installation type	Floor mounted on metal structure
8.	Make of Membrane	Ion Exchange / Eureka Forbes / Kent
9.	Provision of auto backwash	Provision of backwash is required.
10.	TDS controlling	There should be provision to regulate the TDS of outlet purified water and TDS meter for running water
11.	Operating Hours	24 Hours
12.	Electricity	220V, 50Hz
13.	TDS of Output water	50 to 150 ppm