



All India Institute of Medical Sciences Jodhpur

Dated: 09th June, 2016

CORRIGENDUM/ ADDENDUM

For

Rate Contract for Supply of Electrical Items

NIT No. : Admn/RC/01/2016-AIIMS.JDH.
NIT Issue Date : 13th April, 2016
Revised Last Date of Submission : 14th June, 2016 at 03:00 PM.

Page No 16-19 Annexure - IV (Technical Specification).

For-

S. No.	S. No. in NIT	Item detail	Make and Model
1.	12	Providing 1.1 KV grade, ISI marked, electrical insulating tap roll.	Rainbow
2.	16-21	Providing four pole, 100Amps, 415 volts, isolator for the existing MCB DB	Schneider(Acti9)/ Legrand(Lexic)/ ABB(SH200M)
		Providing four pole, 63Amps, 415 volts, isolator for the existing MCB DB	Schneider(Acti9)/ Legrand(Lexic)/ ABB(SH200M)
		Providing four pole, 40Amps, 415 volts, isolator for the existing MCB DB	Schneider(Acti9)/ Legrand(Lexic)/ ABB(SH200M)
		Providing double pole, 63Amps, 240 volts, isolator for the existing MCB DB	Schneider(Acti9)/ Legrand(Lexic)/ ABB(SH200M)
		Providing double pole, 40Amps, 240 volts, isolator for the existing MCB DB	Schneider(Acti9)/ Legrand(Lexic)/ ABB(SH200M)
		Providing double pole, 32Amps, 240 volts, isolator for the existing MCB DB	Schneider(Acti9)/ Legrand(Lexic)/ ABB(SH200M)
		Providing four pole, 100Amps, 415 volts, isolator for the existing MCB DB	Schneider(Acti9)/ Legrand(Lexic)/ ABB(SH200M)
3.	27	Providing piano type bell push/ one way switch on the existing switch box/ cover	SSK EL
4.	30	Providing 20 amps, 240 volts, SPN industrial type socket outlet, with 2 pole and earth, metal enclosed plug top along with 20 amps "C" curve, SP MCB in sheet steel enclosure on surface or in recess with chained metal cover for the socket out let and complete with all connections and accessories as required	Anchor/ Cona/ Vinay
5	56	2C x 1.5 sqmm. ISI marked, FRLS PVC insulated, single core copper conductor cable	PolyCab/ Finolex/ RR Kable
	57	2CX2.5 sq. mm ISI marked, FRLS PVC isolated single core copper conductor cable	PolyCab/ Finolex/ RR Kable

6.	60	Providing 1.1 kV grade, ISI marked, water proof electrical insulating tap roll	CEAT
	61	Providing 11kV grade, ISI marked HT electrical insulating tap roll.	CEAT

Page No 16-19 Annexure - IV (Technical Specification).

Read -

S. No.	S. No. in NIT	Item detail	Make and Model
1.	12	Providing 1.1 KV grade, ISI marked, electrical insulating tap roll. <u>The tape roll should be at least of size: 18mm X 9mtrs. X 0.125mm.</u>	Rainbow
2.	16-21	Providing four pole, 100Amps, 415 volts, isolator for the existing MCB DB	Legrand DX3
		Providing four pole, 63Amps, 415 volts, isolator for the existing MCB DB	ABB E200 series for 100 amp
		Providing four pole, 40Amps, 415 volts, isolator for the existing MCB DB	
		Providing double pole, 63Amps, 240 volts, isolator for the existing MCB DB	
		Providing double pole, 40Amps, 240 volts, isolator for the existing MCB DB	ABB SHD series for 63 amp, 40 amp, 32 amp
		Providing double pole, 32Amps, 240 volts, isolator for the existing MCB DB	
3.	27	Providing piano type bell push/ one way switch on the existing switch box/ cover <u>The switch must be at least of 6 Amp</u>	SSK EL
4.	30	Providing 20 amps, 240 volts, SPN industrial type socket outlet, with 2 pole and earth, metal enclosed plug top along with 20 amps "C" curve, SP MCB in sheet steel enclosure on surface or in recess with chained metal cover for the socket out let and complete with all connections and accessories as required	ABB/ Legrand/ Seimens/ Schiender
5	56	2C x 1.5 sqmm. ISI marked, FRLS PVC insulated, single core copper conductor cable <u>2 core x 1.5 sq. mm. FRLS PVC insulated flexible copper conductor cable is required.</u>	PolyCab/ Finolex/ RR Kable
	57	2CX2.5 sq. mm ISI marked, FRLS PVC isolated single core copper conductor cable <u>2 core x 2.5 sq. mm. FRLS PVC insulated flexible copper conductor cable is required.</u>	PolyCab/ Finolex/ RR Kable
6.	60	<u>Item to be Deleted</u>	
	61	Providing 11kV grade, ISI marked HT electrical insulating tap roll. <u>The tape roll should be at least of size 18 mm x 20 mtrs.</u>	CEAT

ADDENDUM

The following terms & conditions to be added:-

1. The bidder should be authorized Dealer/ Sub Dealer/Distributor of quoted items.

**Administrative Officer
AIIMS, Jodhpur**