

The tenders for above work were uploaded on eprocure.gov.in and www.aiimsjodhpur.edu.in on Thursday 02<sup>nd</sup> May, 2019.  
Pre Bid meeting was held on 9<sup>th</sup> May, 2019

Following Bidders attended Pre Bid meeting:-

| Sl. No. | Bidder Agency Name                         | Representatives Name | Mobile No. / Contact No. | E-Mail                      |
|---------|--|----------------------|--------------------------|-----------------------------|
| 1.      | M/s. MEC Engineers, Noida                  | Mr. Shatrughan Singh | 9210922370               | mec403@rediffmail.com       |
| 2.      | M/s. Dilip Kumar Mathur, Jodhpur           | Mr. Ankit Mathur     | 8279225300               | ankitmathurengg@gmail.com   |
| 3.      | M/s. Malani Enterprises, Jodhpur           | Mr. Motilal Malani   | 9414196632               | malanienterprises@gmail.com |
| 4.      | Mr. Varshtit Electricals Pvt. Ltd., Jaipur | Mr. Vishnu Dusad     | 9414072084               | Varshtit94@gmail.com        |

Through e-mail


Following Officers / Consultants from AIIMS, Jodhpur side were present in the pre bid meeting:-

| S. No. | Name                 | Designation                                     |
|--------|----------------------|---|
| 1.     | Er. Sunil Mathur     | Superintending Engineer (I/c), AIIMS, Jodhpur   |
| 2.     | Er. Pankaj Saxena    | Executive Engineer (Electrical), AIIMS, Jodhpur |
| 3.     | Er. Kunal Utralia    | Junior Engineer (Electrical), AIIMS, Jodhpur    |
| 4.     | Er. Harshit Bhandari | Junior Engineer (Electrical), AIIMS, Jodhpur    |

Pre-bid queries and reply are as under-

| S. No. | QUERY  | REPLY  |
|--------|--|--|
| 1.     | No querry from - M/s. MEC Engineers, Noida   |  |
| 2.     | No querry from - M/s. Dilip Kumar Mathur, Jodhpur  |  |
| 3.     | No querry from - M/s. Malani Enterprises, Jodhpur  |  |
|        | Querry from - Mr. Varshtit Electricals Pvt. Ltd., Jaipur   |  |
| 4.     | 'We are prospective bidders for your above stated tender while going through you BOQ it is observed item no. 2 & 3 are appeared to be same please clarify that these items are same or different if same then cost of the tender is very high. | The specifications / sizes of both the earthing strips are different i.e. item no. 2 is of 50mm X 6mm copper strip and item no. 3 is of 25mmx5mm copper strip. |

  
**Pankaj Saxena**  
(Er. Pankaj Saxena)  
Executive Engineer (Electrical)  
AIIMS, Jodhpur

  
**Sunil Mathur**  
(Er. Sunil Mathur)  
Executive Engineer (Civil)  
AIIMS, Jodhpur